

City of Leslie

2024 Annual Drinking Water Quality Report

We're pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality of water and services we deliver to you every day. Our goal is to provide you with a safe and dependable supply of drinking water, and we want you to understand, and be involved in, the efforts we make to continually improve the water treatment process and protect our water resources.

Where Does Our Drinking Water Come From?

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. We purchase treated surface water from South Mountain who purchases from Ozark Mountain Regional PWA (OMRPWA) whose source is Lake Bull Shoals. We also purchase treated water directly from OMRPWA. We also purchase treated surface water from West Stone County Water Association. West Stone County Water Association purchased treated surface water from the Mountain View Water Department and Community Water System. Mountain View Water Department's source is White River, and Community Water System's source is Greer's Ferry Lake.

How Safe Is The Source Of Our Drinking Water?

The Arkansas Department of Health has completed Source Water Vulnerability Assessment for Mountain View Water Department, Community Water System and Conway Corporation. The assessments summarize the potential for contamination of our sources of drinking water and can be used as a basis for developing source water protection plans. Based on the various criteria of the assessments, our water sources have been determined to have a low to medium susceptibility to contamination. You may request summaries of these assessments from our office.

What Contaminants Can Be In Our Drinking Water?

As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: Microbial contaminants such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; Inorganic contaminants such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming; Pesticides and herbicides which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; Organic chemical contaminants including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure tap water is safe to drink, EPA has regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Am I at Risk?

All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. However, some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from small amounts of contamination. These people should seek advice about drinking water from their health care providers. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791. In addition, EPA/CDC guidelines on appropriate means to lessen the risk of infection by microbiological contaminants are also available from the Safe Drinking Water Hotline.

Lead and Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

How Can I Learn More About Our Drinking Water?

If you have any questions about this report, or concerning your water utility, please contact Eric Yeager, at 870-447-2240. We want our valued customers to be informed about their water utility. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Monday of each month at 7:00 PM at the Leslie Community Center or City Hall.

TEST RESULTS

We, South Mountain, Mountain View Water Department, Community Water System, Ozark Mountain Regional PWA, and West Stone County Water Association routinely monitor constituents in your drinking water according to Federal and State laws. The test results table shows the results of our monitoring for the period of January 1st to December 31st, 2024. In the table you might find terms and abbreviations you are not familiar with. To help you better understand these terms we've provided the following definitions:

Action Level - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements, which a water system must follow.

Maximum Contaminant Level (MCL) - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - unenforceable public health goal; the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Nephelometric Turbidity Unit (NTU) - a unit of measurement for the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Parts per billion (ppb) - a unit of measurement for detected levels of contaminants in drinking water. One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per million (ppm) - a unit of measurement for detected levels of contaminants in drinking water. One part per million corresponds to one minute in two years or a single penny in \$10,000.

TEST RESULTS						
TURBIDITY						
Contaminant	Violation Y/N	Level Detected	Unit	MCLG (Public Health Goal)	MCL (Allowable Level)	Major Sources in Drinking Water
Turbidity (Mountain View)	N	Highest yearly sample result: 0.305 Lowest monthly % of samples meeting the turbidity limit: 99%	NTU	NA	Any measurement in excess of 1 NTU constitutes a violation A value less than 95% of samples meeting the limit of 0.3 NTU, constitutes a violation	Soil runoff
Turbidity (Community Water)	N	Highest yearly sample result: 0.21 Lowest monthly % of samples meeting the turbidity limit: 100%				
Turbidity (OMRPWA)	N	Highest yearly sample result: 0.374 Lowest monthly % of samples meeting the turbidity limit: 99.5%				
♦ Turbidity is a measurement of the cloudiness of water. It is monitored because it is a good indicator of the effectiveness of filtration systems.						
INORGANIC CONTAMINANTS						
Contaminant	Violation Y/N	Level Detected	Unit	MCLG (Public Health Goal)	MCL (Allowable Level)	Major Sources in Drinking Water
Fluoride (Mountain View)	N	Average: 0.66 Range: 0.34 - 0.73	ppm	4.0	4.0	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Fluoride (Community Water)	N	Average: 0.70 Range: 0.56 - 0.78				
Nitrate [as Nitrogen] (Mountain View)	N	0.27	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Nitrate [as Nitrogen] (Community Water)	N	0.29				
Nitrate [as Nitrogen] (OMRPWA)	N	Average: 0.33 Range: 0.14 - 0.42				
♦ The percentage of Total Organic Carbon (TOC) removal was routinely monitored in 2024 by all our suppliers, and all TOC removal requirements set by USEPA were met. Total organic carbon (TOC) has no health effects; however, total organic carbon provides a medium for the formation of disinfection by-products. These by-products include trihalomethanes (THMs) and haloacetic acids (HAAs).						
LEAD AND COPPER TAP MONITORING						
Contaminant	Number of Sites over Action Level	90 th Percentile Result	Unit	Action Level	Major Sources in Drinking Water	
Lead (City of Leslie)	2 of 20	0.0118	ppm	0.015	Corrosion from household plumbing systems; erosion of natural deposits	
Copper (City of Leslie)	0 of 20	0.265	ppm	1.3		
♦ Leslie is on a reduced monitoring schedule and required to sample once every three years for lead and copper at the customers' taps. Our last monitoring period was 2024. Our next required monitoring period is 2027.						
LEAD SERVICE LINE INFORMATION						
♦ As part of our ongoing efforts to comply with federal regulations, we have developed a service line inventory to identify potential lead service lines within our system. A copy of the inventory is available from our office upon request.						
REGULATED DISINFECTANTS						
Disinfectant	Violation Y/N	Level Detected	Unit	MRDLG (Public Health Goal)	MRDL (Allowable Level)	Major Sources in Drinking Water
Chlorine (City of Leslie)	N	Average: 0.89 Range: 0 - 2.2	ppm	4.0	4.0	Water additive used to control microbes

BY-PRODUCTS OF DRINKING WATER DISINFECTION					
Contaminant	Violation Y/N	Level Detected	Unit	MCLG (Public Health Goal)	MCL (Allowable Level)
HAA5 [Haloacetic Acids] (City of Leslie)	N	0	ppb	0	60
TTHM [Total Trihalomethanes] (City of Leslie)	N	Highest Value: 20.0 Range: 18.6 - 20.1	ppb	NA	80
Chlorite (Community Water)	N	Average: 300 Range: 104 - 359	ppb	800	1000
<ul style="list-style-type: none"> Leslie Water is on a reduced monitoring schedule and required to sample during the second and third quarters of each year for Total Trihalomethanes and Haloacetic Acids in the distribution system. 					

SIGNIFICANT DEFICIENCIES	
Under the Safe Drinking Water Act, each Water Treatment System must be surveyed (audited) by the Arkansas Department of Health and all uncorrected Significant Deficiencies must be identified, corrected and reported to the public. Leslie Water had one Significant Deficiency identified during their July 10, 2023, tank inspection report.	
Nature of Deficiencies	Progress to Date
The concrete storage tank must be patched and a gasket added to the manway access to prevent water and contaminants from entering the tank. The tank must be drained, cleaned, and the structural cracks sealed ASAP.	No progress update received.